Kentucky Electricity Portfolio Model

Developed by

Kentucky Energy and Environment Cabinet

Department for Energy Development Independence


In Partnership with

University of Kentucky Department of Statistics
University of Kentucky Center for Applied Energy Research
Pacific Northwest National Laboratory

May 13th, 2014


Download the Full Report

"Economic Challenges Facing Kentucky's Electricity Generation Under Greenhouse Gas Constraints"




Kentucky Electricity Portfolio Model, EEC-DEDI, 17 Nov 2013 Scenario:1

Kentucky Coal Consumption for Electricity Generation, 1960-2050



Kentucky Natural Gas Consumption for Electricity Generation, 1960-2050






A Quick Introduction to


Kentucky Electricity Portfolio Model

Download the Full Report

"Economic Challenges Facing Kentucky's Electricity Generation Under Greenhouse Gas Constraints"

Original Model Design Plan





Forecast Outputs, 2013-2100


Endogenous Electric Power Factors Electricity Consumption by Sector Electricity Prices by Sector Electricity Expenditures Electricity Generation by Unit **Electric Power Emissions** Natural Gas Consumption Coal Consumption **Endogenous Socioeconomic Factors** Gross Domestic Product (GDP) Per Capita Personal Income Manufacturing Employment Retail Employment Hospitality Employment **Electric Power Employment** Coal Mining Employment Other Employment **Exogenous Independent Factors Temperature** Cooling Degree Days **Heating Degree Days** Rainfall **Population Educational Attainment** Natural Gas Prices


Coal Prices


BACK Main Menu **NEXT** Portfolio

2025 Electricity Portfolio Control Panel

ummary Scenario Statistics Year 2025 Total Electricity Rate Change in Electricity Rate -32.9684% Change in GHG Emissions READY Model Status







40%

CO

-29.2450%

54,425.5768

0.0000%

18.07

Edit Elasticity

60%

80%

100%

Particulates

-14.2350%

12,353.3196

3.0533%

383 ~MVVe





18.8958%

17.667.858



KY Wind

0.0600%

32 MW

\$120

0.53%

NOX

-27.0835%



Imported Wind

0.0000%

SO₂

-39.9922%

183,460.99




Solar

0.4853%

CH4

-12.6774%



0.0000%

N20

-15.1773%

2,008.3254

0%

20%








Dairy Cattle

0.0001%






























Version 2.0 Behind the Scenes



Environmental Regulations


The dispatch optimization algorithm will adhere to any combination of the following types of environmental constraints, which will never be violated or ignored.


- Portfolio CO₂ mass emissions limits can be specified in lbs in any year.
 When violated, algorithm will achieve compliance by optimizing on \$ per LB of CO₂ reduced.
- Portfolio CO₂ emission rate limits can be specified in **lbs per MWh** in any year.

 When violated, algorithm will achieve compliance by optimizing on \$ per LB of CO₂ reduced.
- Unit-level CO₂, SO₂, and NO_X limits can be specified in lbs per MWh in any year.
 Units in violation will be retired.
- New Source Performance Standards for CO₂, SO₂, and NO_X limits in lbs per MWh.


 Units in violation will not be built.
- CO₂, SO₂, and NO_X fines can be specified in \$ per lb in any year.


 Cost of emissions is incorporated into Variable Operations and Maintenance (VOM) costs. The unit will be run if it remains least-cost despite the fine, otherwise the next cheapest technology will be used.






Kentucky Electricity Portfolio Model, EEC-DEDI, 17 Nov 2013 Scenario:1






Kentucky Electricity Portfolio Model, EEC-DEDI, 26 Nov 2013 Scenario: 14




Kentucky Electricity Portfolio Model, EEC-DEDI, 17 Nov 2013 Scenario:14





Kentucky Electricity Portfolio Model, EEC-DEDI, 3 Nov 2013, Scenario: 12




Kentucky Electricity Portfolio Model, EEC-DEDI, 17 Nov 2013 Scenario:12

Portfolio Standards


The dispatch model algorithm has a versatile set of portfolio standard options, designed to process most types of portfolio standards. The algorithm will search for the least-cost portfolio that satisfies the portfolio standard.

- Staff can specify a "category" and determine what types of generation are part of this category. An example of a category could be "renewables" or "coal".
- A category minimum portfolio standard can be specified in MWh and/or as a
 percentage of total generation in every year.
- A category maximum portfolio standard can be specified in MWh and/or as a percentage of total generation in every year.
- Unlike Version 1.0 of the Portfolio Model, where the user specified exactly how electricity would be generated by optimizing within constraints, Version 2.0 more realistically mimics real world market dynamics.

Kentucky Electricity Generation, 2085



Coal Nuclear Hydro




Kentucky Electricity Portfolio Model, EEC-DEDI, 25 Apr 2014 Scenario:26

Hierarchical Constraints

The dispatch model algorithm has a variety of complex and potentially conflicting user-specified constraints.

- 1. Physical resource and technology limitations define the parameters of what is possible.
- 2. Environmental regulations, including portfolio carbon dioxide emission rate or mass limits or unit-level CO_2 , SO_2 , or NO_X limits will not be violated, regardless of costs or implications.
- 3. Electricity demand will be met so long as there are resources to do so without violating environmental constraints.
- 4. Portfolio Standards will be adhered to so long as they are physically possible and do not violate environmental regulations. Portfolio standards that conflict with environmental constraints, or that are not achievable will be ignored.
- 5. Least-cost electricity will be delivered while above constraints are satisfied.




Kentucky Electricity Portfolio Model, EEC-DEDI, 25 Apr 2014 Scenario:28

Unit Retirements

The dispatch algorithm can autonomously choose to retire existing and future electricity generation units for one or more of the four following reasons.


- 1. Environmental retirements occur when the unit's individual emissions of a criteria pollutant violate the maximum allowable emissions rates or when shutting off the unit is the least-cost means of complying with a portfolio-wide CO2 emissions standard.
- **2. Economic retirements** occur when the total costs of continuing to operate a generating asset are higher than the costs of abandoning the asset, including the capital invested into it, and building and operating a suitable replacement. An economic retirement can also occur if the unit is no-longer needed to generate electricity.
- **3. Age-out retirements** occur when the unit has exhausted its usable system life as specified in its physical characteristics.
- **4. Staff-specified retirements** occur when the planned date that a particular unit will go offline has already been made known to staff, either publically or confidentially, by the owner or government regulator of the asset.



Kentucky Electricity Portfolio Model, EEC-DEDI, 1 Nov 2013 Scenario:10


Kentucky Costs of Electricity Generation by Technology, 2030


Low Carbon Technologies Only (<=1.1lbs per kWh)



Kentucky Energy Database, EEC-DEDI, 2013 Kentucky Electricity Portfolio Model

Detailed Cost Data Available on Pages C.89 and C.90 of Complete Report







Kentucky Energy Database, EEC-DEDI, 2013

Kentucky Electricity Portfolio Model

Technology	2030 Cost (\$ per kWh)	Primary Fuel	Nameplate (MW)	Capacity Factor	\$/kW	\$/kW-yr	\$/MWh	System Life	Heat Rate	Lead Time (Years)		NO _x (lb./MWh)	SO ₂ (lb./MWh)
Biomass Combined Cycle	\$0.21079	Biomass	20	0.83	8180	356.07	17.49	30	12350	5	0	0.09	0
20 MW Photovoltaic	\$0.19691	Solar	20	0.25	4183	27.75	0	30	0	2	0	0.01	0
150 MW Photovoltaic	\$0.18186	Solar	150	0.25	3873	24.69	0	30	0	2	0	0.01	0
Fuel Cells	\$0.18170	Natural Gas	10	0.9	7108	0	43	30	9500	2	1235	0.1235	0.00124
Single Unit IGCC with CCS	\$0.13668	Coal	520	0.83	6599	72.83	8.45	30	10700	7.5	220	0.08025	0.1605
Single Unit Advanced SCPC with CCS	\$0.12244	Coal	650	0.85	5227	80.53	9.51	30	12000	7.5	247	0.72	0.24
Biomass Bubbling Fluidized Bed	\$0.11795	Biomass	50	0.78	4114	105.63	5.26	30	13500	3.5	0	1.08	0
Dual Unit Advanced PC with CCS	\$0.11403	Coal	1300	0.85	4724	66.43	9.51	30	12000	9	247	0.72	0.24
Combustion Turbine	\$0.11308	Natural Gas	85	0.3	973	7.34	15.45	30	10850	3	1269	0.3255	0.01085
USCPC with CCS	\$0.11145	Coal	550	0.85	5130	47.3	9.2	30	10270	12.5	205	0.7189	0.00001
USC with Oxy Combustion CCS	\$0.10469	Coal	550	0.85	4770	45.55	7.1	30	10353	12.5	135	0.72471	0.21741
Single Unit IGCC	\$0.09752	Coal	600	0.85	4400	62.25	7.22	30	8700	6.5	1792	0.065	0.2175
Imported Wind	\$0.09468	Wind	30	0.34	2513	39.55	0	30	0	2	0	0.01	0
Advanced Combustion Turbine	\$0.09100	Natural Gas	210	0.3	676	7.04	10.37	30	9750	3	1141	0.2925	0.00975
Dual Unit Nuclear Reactor	\$0.08915	Uranium	2234	0.9	5530	93.28	2.14	30	10452	11	0	0.01	0
Dual Unit IGCC	\$0.08809	Coal	1200	0.85	3784	51.39	7.22	30	8700	8	1792	0.065	0.2175
Small Modular Nuclear Reactors	\$0.08267	Uranium	180	0.9	5000	93.28	2.14	30	10452	9	0	0.01	0
Advanced NGCC with CCS	\$0.07846	Natural Gas	340	0.87	2095	31.79	6.78	30	7525	5	90	0.05644	0.00753
Single Unit Advanced SCPC	\$0.07683	Coal	650	0.85	3246	37.8	4.47	30	8800	6.5	1813	0.528	0.88
USCPC with 20% Biomass	\$0.07345	Cofire	650	0.85	3147	31.18	4.47	30	8800	6.5	1496	0.53	0.88
Dual Unit Advanced SCPC	\$0.07190	Coal	1300	0.85	2934	31.18	4.47	30	8800	8	1813	0.528	0.88
Ultra-Supercritical PC	\$0.07060	Coal	550	0.85	3000	34.16	5.2	30	7654	6.5	1554	0.53578	0.65824
Combined Heat & Power	\$0.06864	Natural Gas	10	0.87	2278	7.5	6.1	30	6007	2.5	364	0.1802	0.006
Conventional Hydroelectric	\$0.06528	Hydro	10	0.52	2936	14.13	0	30	0	6	0	0	0
Natural Gas Retrofit of SC PC Boiler	\$0.06101	Natural Gas	250	0.87	250	25	3.6	30	9355	2	1095	0.28065	0
Municipal Solid Waste Combustion	\$0.05587	LFG	20	0.85	4001	97.1	-9	30	18000	3.5	0	4.86	1.26
Natural Gas Combined Cycle	\$0.05534	Natural Gas	620	0.87	917	13.17	3.6	30	7050	3.5	825	0.05288	0.00705
Advanced NGCC	\$0.05327	Natural Gas	400	0.87	1023	15.37	3.27	30	6430	3.5	752	0.04823	0.0064
Municipal Solid Waste Gasification	\$0.05118	LFG	27	0.85	3784	90.5	-10	30	13600	5	0	3.67	0.952
USCPC with 20% Biomass - Retrofit	\$0.03230	Cofire	650	0.85	213	1.06	0.45	30	10600	2	1802	0.64	1.06

Kentucky Employment Forecast, 1970-2050





Kentucky Electricity Portfolio Model, EEC-DEDI, 11 Nov 2013

Change in Employment, 2035

(Full Time Jobs)

	Portfolios							
Federal Policy Options	1: Nuclear Banned	2: Nuclear Allowed	3: Balanced Portfolio	4: Coal Portfolio				
1: Reference Case	0	0	0	0				
2: Carbon Price: \$10 - \$20	-60,000	-60,000	-60,000	-70,000				
3: Carbon Price: \$20 - \$40	-110,000	-110,000	-110,000	-130,000				
4: Carbon Price: \$40 -\$60	-130,000	-130,000	-130,000	-170,000				
5: CO2 Rate Limit	-70,000	0	0	NA				
6: Presidential CO2 Rate Limit	-70,000	-20,000	-40,000	NA				
7: Mass Emissions Reduction	-70,000	-30,000	-40,000	NA				

Change in Employment, 2035

(Percent)								
	Portfolios							
Federal Policy Options	1: Nuclear Banned	2: Nuclear Allowed	3: Balanced Portfolio	4: Coal Portfolio				
1: Reference Case	0.00%	0.00%	0.00%	0.00%				
2: Carbon Price: \$10 - \$20	-2.11%	-2.11%	-2.11%	-2.45%				
3: Carbon Price: \$20 - \$40	-3.87%	-3.87%	-3.87%	-4.55%				
4: Carbon Price: \$40 -\$60	-4.58%	-4.58%	-4.58%	-5.94%				
5: CO2 Rate Limit	-2.46%	0.00%	0.00%	NA				
6: Presidential CO2 Rate Limit	-2.46%	-0.70%	-1.41%	NA				
7: Mass Emissions Reduction	-2.46%	-1.06%	-1.41%	NA				

Contact Information

Aron Patrick

Assistant Director Aron.Patrick@ky.gov

Adam Blandford

Energy Analyst

Adam.Blandford@ky.gov

Kentucky Energy and Environment Cabinet
Department for Energy Development & Independence
502-564-7192

Twitter: **@KYDEDI**

Facebook: <u>facebook.com/KentuckyDEDI</u>

Website: energy.ky.gov